CITY OF JOPLIN
ADDENDUM NUMBER 1

Issued to all Bid Document Holders of Record.

Date: 2/22/2022

Project Name: Parking Lot and Trail Sealing 2022

This addendum forms a part of the contract described above. The original Contract Documents and any prior addenda remain in full force and effect as modified by the following that shall take precedence over any contrary provisions in the prior documents.

1) **The following page provides answers to questions that arose in the pre-bid meeting.**

David K. Hertzberg, PE
Director of Public Works

2/22/22
Date

Each bidder shall acknowledge receipt of this addendum by affixing his signature below by noting this addendum on his bid form, and by attaching this addendum to his bid.

ACKNOWLEDGEMENT
The undersigned acknowledges receipt of this addendum and the Bid submitted in accordance with information, instructions and stipulations set forth herein.

Bidder: _____

Signed By: _____

Date: _____

Pre-Bid Questions and Answers

1) **How many lots can be closed at once?** Most lots can be closed fully and in conjunction with each other if needed. The exception is the golf course lot as it will need to be split into two separate days to allow the lot to be accessible.
2) **Is the contractor responsible for repainting the parking stalls?** No, city crews will restripe the lots.
3) **Will the City allow for one coat of seal to be sprayed on and the other squeegeed as opposed to both being squeegeed by the specifications?** Yes, the City will allow this.