City of Joplin Dover Outdoor Recreation Area Bicycle Park
ADDENDUM NUMBER 5

DATE: November 5, 2024

TO: Prospective Bidders

OWNER: City of Joplin
602 South Main Street
Joplin, Missouri 64801

LANDSCAPE ARCHITECT: SWT Design, Inc.
1925 Central Street
Kansas City, Missouri 64108

ENGINEER: Civil & Survey, LLC
2419 South 11th Street
St. Louis, Missouri 63104

SUBJECT: Addendum Number 5 to the Bidding Documents for
City of Joplin Dover Recreation Area Bicycle Park
SWT Project No. 21703.01
C&S Project No. 24002

This 1-page Addendum forms a part of the Bidding and Contract Documents and modifies the original Bidding Documents, dated October 7, 2029. **FAILURE TO ACKNOWLEDGE RECEIPT OF ADDENDUM MAY SUBJECT BIDDER TO DISQUALIFICATION.**

ITEMS

Addendum 5 provides the following clarifications:

1. The thickness of BP-2 asphaltic concrete is 3" in all areas of full depth pavement.

2. The pavement repair item shown on the Bid Form will be used as needed at locations determined during construction.

This Addendum consists of 1 page.

END ADDENDUM NUMBER 5