March 15, 2018

CITY OF JOPLIN
SENIOR CENTER PHASE 2
KITCHEN EQUIPMENT
CDBG-DR GRANT NO. B-12-MT-29-0001

Addendum No. 01

Contract Bidders:

Enclosed is Addendum No. 1 for the above referenced project. Please execute, attach, and submit this Addendum No. 1 with your bid.

Bates Architects

James Damron

_____
Company Name

_____
Signature

_____
Printed Name

CITY OF JOPLIN
SENIOR CENTER PHASE 2
KITCHEN EQUIPMENT
CDBG-DR GRANT NO. B-12-MT-29-0001

Addendum No. 01

Proposal Items:

Question #1: Item 3 Shelving Unit - Drawing shows five (5) and the written specifications call for three (3). Please advise.

Area Agency Response: The specifications of three (3) is correct.

Question #2: Item #17 –the drawings show the mixer to be new but not listed in the written specifications.

Area Agency Response: This is existing and will be moved from existing facility. Do not include in bid.

Question #3: Item 19 Range - Drawing shows to provide with spark ignition but no mention of that option in the written specifications.

Area Agency Response: Spark ignition is required.

Question #4: Item 32 Ice Machine - Drawing shows this to be existing but the written specifications call for a new machine.

Area Agency Response: This item will need to be included in the bid.

Question #5: Item 33 Storage Bin - Drawing shows this to be existing but the specifications call for a new bin.

Area Agency Response: This item will need to be included in the bid.

Question #6: Item 35 Can Rack - Drawing shows this to be new but not listed in the written specifications.

Area Agency Response: This is existing and will be moved from existing facility. Do not include in bid.

Question #7: Item 38 Beverage Counter - Drawing shows this to be new but not listed in the written specifications.

Area Agency Response: This is being provided and installed by the General Contractor.

Question #8: Item 41 Exhaust Hood - Written specifications do not mention anything about fans & duct work. Are they being provided by the HVAC contractor (which would be typical)?

Area Agency Response: As per sheet M1.01 of the building set: The hood, exhaust fan and make-up air unit is to be provided by the kitchen equipment supplier and installed by the mechanical contractor. The General Contractor confirmed this correct.