CITY OF JOPLIN
ADDENDUM NUMBER 1

Issued to all Bid Document Holders of Record.

Date: 2/18/2021

Project Name: Microsurfacing 2021

This addendum forms a part of the contract described above. The original Contract Documents and any prior addenda remain in full force and effect as modified by the following that shall take precedence over any contrary provisions in the prior documents.

1) **The following page provides answers to questions that arose in the pre-bid meeting.**
2) **The contract indicates that the completion date of the project is June 30, 2021. This will be amended to be 90 days from the notice to proceed date. The City will work with the contractor to set a reasonable notice to proceed date that works for both parties.**
3) **Truck mounted equipment will be allowed for the application of material on the parking lots as long as the quality of the finished product is not affected.**
4) **Due to the delay of issuing this addendum, questions will be accepted until 5:00 pm Friday, February 19. If there are any questions that arise that call for an addendum, it will be put out on the following Monday.**

David K. Hertzberg, PE
Director of Public Works

2/17/2021
Date

Each bidder shall acknowledge receipt of this addendum by affixing his signature below by noting this addendum on his bid form, and by attaching this addendum to his bid.

ACKNOWLEDGEMENT
The undersigned acknowledges receipt of this addendum and the Bid submitted in accordance with information, instructions and stipulations set forth herein.

Bidder: _____

Signed By: _____

Date: _____

Pre-Bid Questions and Answers

1) **Will Type II aggregate be allowed in the parking lots?** Yes, Type II aggregate will be allowed in the parking lots.
2) **Can work be done on the weekend for the Wastewater Treatment Plant?** Yes, work may be done on Saturdays if needed and it would probably be easier for coordination if it is done on a Saturday. Contractor will be required to work with the Wastewater Treatment Plant staff when coordinating schedule. Contacts will be provided to contractor.
3) **Who is responsible for removing the parking blocks in the parking lots?** City crews will remove the parking blocks prior to contractor arriving to micro-surface.
4) **Will contractor be responsible for repainting the parking stalls on the parking lots?** No, the lots will be restriped by city crews.
5) **Can "the 40" (area of city property off North Schifferdecker) be used as a staging area?** Yes. Location must be coordinated to make sure all equipment in out of the way. The area is not secured so the contractor assumes any and all risk of damages/vandalism to anything stored at the location.
6) **What is to be used for any markings that must be replaced in the roadway?** I am not aware of any striping or crosswalks on any of the streets that are to be resurfaced, however if there are any, crosswalks are to be put back with thermoplastic and centerline striping may be done with paint or thermoplastic.