More Contractor Questions

1. **You have stated that the concrete rubble and foundation can be crushed and left on site, is there a certain size of product that you are wanting, Most people crush to at least a 4 " minus size. Can we have larger pieces or is it expected that everything will need to be 4 " minus**

Answer: Crushed concrete must be 4" minus in order to be used as fill.

2. **During the job walk, many contractors were talking about the asbestos survey. Noting specifically that there was a lot more abatement that needed to be done compared to what the survey was saying. Do you want a line item price for extra fittings, floor tile/mastic, door glazing, and TSI for our bid?**

Answer: Some of the asbestos noted in the report did not include a quantity. However, we are needing a complete bid and not a line item cost so we are asking contractors to bid accordingly.

3. **Will there be a cost for the demolition permit?**

Answer: A $75 demolition permit will be required.

4. **Will utility companies kill their respective utilities or will there be costs for the contractor?**

Answer: The demolition permit application requires the contractor to coordinate with the different utility companies to remove any of their services however the actual cost is covered by the utility companies themselves.