City of Joplin
Notification to Bidders

Issued to all Bid Document Holders of Record.

Date: 7/31/2020

Project Name: Fire Station Concrete Apron Approach Project

This notification serves to inform of an addendum that should be posted on Monday, August 3rd. After discussion with the consultant, the City of Joplin will be requiring the addition of steel reinforcement to the concrete. An official addendum showing a standard detail of the reinforcement will be issued on Monday. In addition to this change, the addendum will also include a special provision calling for all control joints to be sealed.

Normally a notification would not be sent out prior to an addendum, however, since the standard detail will not be available until Monday, I wanted to issue this notice to provide as much advanced warning as possible.

Thanks,

Dakota Rusk